

**Sede legale:**

Via del Commercio, 6/A  
60030 Monte Roberto (AN)  
T: +39 0731 22781  
F: +39 0731 227806  
E: info@tuvaustraiitalia.com  
tuvaustraiitalia@legalmail.it  
W: www.tuvaustraiitalia.com  
Codice Sdl M5UXCR1

**Sede operativa:**

Via dell'Industria, 14  
25030 Erbusco (BS)  
T: +39 030 982 1049  
F: +39 030 982 2253  
E: info.bs@tuvaustraiitalia.com

**Sede operativa:**

Via Pasquale Romano, 25  
72100 Brindisi (BR)  
T: +39 347 597 0825  
F: +39 030 982 2253  
E: info.br@tuvaustraiitalia.com

TÜV®

Report no.: TAI-FS-R-21-0175

**SIL SUMMARY REPORT**

**IEC 61508-1/7:2010**

**Pneumatic / hydraulic compact scotch-  
yoke double acting actuator**

**Series RC**

**Rotork Sweden AB  
Kontrollvägen, 15  
SE-791 22 Falun**

Date: 2021-08-04

Author  
Carlo Tarantola



Signature

*This document is only valid in its entirety, without any change.*

## 0 STATUS OF THE DOCUMENT

History: R 00: Initial release  
Release status: Released to client  
Author(s): Carlo Tarantola

Date: 2021-08-04

## 1 INTRODUCTION

This report is related to the assessment according to standards:

IEC 61508-1/7:2010

for the following products:

pneumatic / hydraulic compact scotch-yoke double acting actuator series RC

NOTES:

- The results of this report can be used for the assessment of a complete Safety Instrumented System.

## 2 ASSESSMENT AND RESULTS

Product identification		
Device	Pneumatic / hydraulic compact scotch-yoke double acting actuator	
Series	RC	
Models / configurations	RC - No PST RC - With PST RC88 - No PST RC88 - With PST	
Safety function(s)		
1.	Delivery of a full stroke (90° ± tolerance) driven by the piston of cylinder, powered by the specified medium working pressure. NOTE: considering the functioning of the actuator to perform the safety function(s), the safety functions "close" and "open" can be considered equivalent.	
Mode of operation of the safety function(s)	Low demand mode	
Reference standards		
General functional safety standard	IEC 61508-1/7:2010	
Product specific functional safety standard	None	
Assessment phases		
Management of functional safety / functional safety planning	Assessed	A functional safety audit of the management systems and of the functional safety planning is conducted to document and highlight that the development of the product under consideration is compliant with IEC 61508.
Safety requirements specification	Assessed	The Safety requirements specification is assessed with respect to its consistency and completeness in a comparison with the applicable requirements of IEC 61508.

Design	Assessed	The assessment of the design included the following aspects: <ul style="list-style-type: none"> <li>Quantifiable aspects: random failure rates, DC, SFF, PFD<sub>AVG</sub>, <math>\beta</math> factors, MRT, PTC, architectural constraints</li> <li>Non-quantifiable aspects: behaviour of the safety function under fault conditions, safety-related software (not applicable to the product under consideration), systematic failures, behaviour under environmental conditions</li> </ul> See below for the results.
Verification and Validation	Assessed	The verification and validation activities performed by the manufacturer include review, analysis and tests.
Information for use	Assessed	The assessment covers: <ul style="list-style-type: none"> <li>the installation, operation and maintenance instructions (IOM Manual)</li> <li>the particular instructions required by Annex D of IEC 61508 Part 2 (Safety Manual)</li> </ul>
Modification	Assessed	Procedures for modification activity are described in specific documents, referenced in the safety planning.

## Results

Selected assessment routes	<ul style="list-style-type: none"> <li>For architectural constraints: Routes 1<sub>H</sub> and 2<sub>H</sub></li> <li>For Systematic Capability: Route 1<sub>s</sub></li> </ul> Furthermore, the requirements in paragraphs 7.4.10.1–7.4.10.7 of IEC 61508 Part 2 are assessed and considered fulfilled, as: <ul style="list-style-type: none"> <li>the product has a restricted and specified functionality and is designed to perform specified safety functions</li> <li>the product has an adequate documentary evidence (including extensive operating experience and results of suitability analysis and testing), sufficient to claim the declared failure rates</li> <li>the manufacturer has an effective system for reporting failures</li> </ul>			
Element type (A or B)	Type A			
HFT	The product has a single channel configuration, HFT=0.			
Random failure rates	The determination of random failure rates is performed with a FMEDA, integrated with field feedback, according to IEC 61508 Part 2 Par. 7.4.4.3.3, using the Bayesian approach.			
Configuration	Safety function	$\lambda_{DU}$ [1/h]	$\lambda_{DD}$ [1/h]	$\lambda_S$ [1/h]
RC - No PST	1	2,29E-08	0,00E+00	0,00E+00
RC - With PST	1	2,06E-09	2,09E-08	0,00E+00
RC88- No PST	1	3,46E-08	0,00E+00	0,00E+00
RC88 - With PST	1	3,11E-09	3,15E-08	0,00E+00
Spurious trip rate	0,00E+00 [1/h] NOTE: failures of components of the cylinder cannot generate spurious trips. The "spurious trip rate" is therefore 0,00E+00 [1/h]			
DC	The product does not include internal diagnostics. Diagnostic is only be possible via external means, e.g. with a PST. The procedure for the PST is described in the Safety Manual.			

SFF	<p>Considering that <math>\lambda_S=0</math>, according to definitions 3.6.15 of IEC 61508 Part 4:</p> <ul style="list-style-type: none"> <li>SFF=0 without external diagnostic tests</li> <li>SFF&gt;0 with external diagnostic tests, carried out according to definition 3.8.7 of IEC 61508 Part 4, and according to what written in the Safety Manual</li> </ul>
PFD <sub>AVG</sub>	<p>As the PFD<sub>AVG</sub> value depends also on the test intervals and on the PTC and the coverage of external tests, which are not product-dependant quantities, the PFD<sub>AVG</sub> values are not product relevant quantities, while <math>\lambda</math> values are.</p> <p>Anyway, PFD<sub>AVG</sub> values are calculated for a certain number of combination of test intervals.</p> <p>See Annex A.</p>
$\beta$ factors	<p><math>\beta=\beta_D=0,05</math></p> <ul style="list-style-type: none"> <li>The above value is the value for 1oo2 architecture. The values for other architectures shall be calculated according to IEC 61508 Part 6, Table D.5.</li> <li>The above value is calculated in the hypothesis of redundancy without diversity</li> </ul> <p>The <math>\beta</math> factors can be used when performing PFD<sub>AVG</sub> calculations for redundant architectures.</p>
MRT	<p>24 h</p> <p>The MRT considered is the Technical Mean Repair Time, i.e., it takes in consideration availability of skilled personnel, adequate tools and spare parts.</p>
PTC	<p>The procedure for the Proof Test is described in the Safety Manual.</p>
Architectural constraints	<p>The product can be used in:</p> <ul style="list-style-type: none"> <li>single channel configuration: <ul style="list-style-type: none"> <li>up to SIL 2 without external diagnostic tests</li> <li>up to SIL 3 considering external diagnostic tests</li> </ul> </li> <li>double channel configuration: up to SIL 3</li> </ul>
Expected lifetime	<p>25 years</p>
Behaviour of the safety function under fault conditions	<p>The product does not include internal diagnostics.</p>
Safety related SW	<p>No SW is used to implement the safety function.</p>
Systematic Capability	<p>3</p>
Behaviour under environmental conditions	<p>The behaviour in environmental conditions is assessed evaluating the relevant environmental tests.</p>
Limitations for use	<p>Make reference to the Safety Manual.</p>
<b>Remarks</b>	
<ul style="list-style-type: none"> <li>The random failure rates in the above table are valid for all the possible configurations of the product.</li> <li>According to the definition of IEC 61508 (in particular definitions 3.6.8 and 3.6.13 of IEC 61508 Part 4), no Safe Failures are possible in a double acting actuator: each failure mode of the actuator itself shall be classified as “Dangerous” or “No Effect” (failures which can generate the spurious operation of the safety function are only external to the actuator itself, and even in the case of loss of power supply the actuator “stays put”); hence, <b><math>\lambda_S=0</math> for each type of double acting actuator.</b></li> <li>Failures of components of the cylinder cannot generate spurious trips. The “spurious trip rate” is therefore 0,00E+00 [1/h]</li> <li>The <math>\lambda_S</math> values are not divided in <math>\lambda_{SD}</math> and <math>\lambda_{SU}</math>, as this subdivision has no relevance for any of the SIL parameters.</li> <li>For further details, make reference to the Safety Manual.</li> </ul>	

Reference documents	
SIL Assessment Report	TÜV AUSTRIA document no. TAI-FS-R-21-0174
Safety Manual	Rotork document no. SM-RC-A-00-E

## ANNEX A - EXAMPLES OF PFD<sub>AVG</sub> CALCULATIONS

Type: RC - No PST – Safety function: 1

Proof test interval (months)				
6	12	24	36	48
5,07E-05	1,01E-04	2,01E-04	3,02E-04	4,02E-04

Type: RC - With PST – Safety function: 1

		Proof test interval (months)				
		6	12	24	36	48
PST interval (months)	1	1,27E-05	1,72E-05	2,62E-05	3,53E-05	4,43E-05
	2	2,03E-05	2,48E-05	3,38E-05	4,29E-05	5,19E-05
	3	2,79E-05	3,24E-05	4,15E-05	5,05E-05	5,95E-05
	6		5,53E-05	6,43E-05	7,33E-05	8,24E-05
	9				9,62E-05	
	12			1,10E-04	1,19E-04	1,28E-04

Type: RC88 - No PST – Safety function: 1

Proof test interval (months)				
6	12	24	36	48
7,65E-05	1,52E-04	3,04E-04	4,55E-04	6,06E-04

Type: RC88 - With PST – Safety function: 1

		Proof test interval (months)				
		6	12	24	36	48
PST interval (months)	1	1,91E-05	2,59E-05	3,96E-05	5,32E-05	6,68E-05
	2	3,06E-05	3,74E-05	5,10E-05	6,47E-05	7,83E-05
	3	4,21E-05	4,89E-05	6,25E-05	7,62E-05	8,98E-05
	6		8,33E-05	9,70E-05	1,11E-04	1,24E-04
	9				1,45E-04	
	12			1,66E-04	1,79E-04	1,93E-04

### NOTES:

- The above values of PFD<sub>AVG</sub> are calculated for MRT=24 h and proof test coverage=100%. For other values of MRT, TI, TI<sub>PS</sub> and/or non-perfect proof test, the PFD<sub>AVG</sub> values must be re-calculated.
- The PFD<sub>AVG</sub> values including partial stroke test are calculated considering the use of a commercial automatic partial stroking test system: for further details, see the Safety Manual.

The values in the above tables are compatible with SIL 3.